CHLORINE INSTITUTE

#### http://www.bisaninc.com Email: <u>sales@bisaninc.com</u>

## **EMERGENCY KIT "B"**

### FOR ONE TON CHLORINE CONTAINERS



The Chlorine Institute Emergency Kit "B" is manufactured to the design specifications of the Chlorine Institute.

The Emergency Kit "B" contains devices to stop leaks at the valves, fusible plugs, and in the side wall of chlorine one ton containers which conform to specification DOT 106A500X. Two instruction booklets explaining the application of each device are included. An instruction DVD for Kit "B" is also available.

#### **EMERGENCY KIT "B" FEATURES:**

**Device #14**: NEW capping device designed to contain leaks in and around ton container fusible plugs without touching the plug itself using the new bar assembly #28C.

**Device #12**: NEW design to contain leaks in and around the ton container valves with spring loaded, adjustable yoke assembly.

**Device #9**: NEW patching device designed for sealing leaks in the ton container side wall with much less torque with fewer pressure points than previous design.

Kit B also includes a variety of hand tools, inspection seals and additional sealing devices. All items are labeled with a part number, color coded yellow and stored inside a durable polyethylene tool box.

#### EMERGENCYKIT "B" TRAINING DEVICES


The **Chlorine One End Training End** is an actual full size end of the standard DOT106A500X container designed to simulate valve and fusible plug leaks for training upon, part #END.

**Kit "B" Instruction DVD** part# BLAV patching device designed for sealing leaks in the ton container side wall with much less torque with fewer pressure points than previous design.


http://www.bisaninc.com Email: <a href="mailto:sales@bisaninc.com">sales@bisaninc.com</a>

# **EMERGENCY KIT "B"**

Applications and Parts List



**DEVICE 12** 



**DEVICE 14** 

Part #	Name	Quantity per Kit
14A 4G	Hood Assembly Gasket, 15/16 dia. x 1/16	1 5
9S 9B 9C1 9D1 9GV	Strap Yoke Cap Screw Steel Patch Gasket, Viton**, 1-1/2" dia. x 3/4" thick Buttor	1 1 1 1 1
12A 4-12BMV 12BBV 12MV	Hood Assembly with (12V) Vent Valve Gasket, Molded Viton**, 4" OD x 2-5/8 ID x 1/4 Gasket, Viton, 5" OD x 2" ID x 1/2 Th. Gasket, Molded Viton**, 5-1/4 OD x 2-1/4 ID x	1
28C	Bar Assembly, Adjustable with center screw 28I	) 1
101 104 104B 106 200B	Wrench, straight open end, 1-1/4 x 12 Wrench, 1-1/4 hex x 8 lg. Wrench, crowfoot special, 1-5/32 x 11 Wrench Bar, 1" dia. x 20" long Wrench, 3/8 sq. box & 1-1/4 open end x 7-1/4	1 1 1 1
B-1 B-2 B-3 B-4	Drift Pin, 5/32 x 1/2 x 6 Drift Pin, 7/8 x 1-1/4 x 8 Drift Pin, 1-1/16 x 1-7/16 x 8 Ring, vent valve packing, 7/8 OD x 15/32 ID x	2 2 2 1/4 5
B-5 B-6 B-7 B-8 B-9 B-10 B-11	sq. Paint Scraper, 1-1/4 blade Hammer, Machinist 3 lb. Kit box Seal Gasket Sack Valve Yoke Valve Adapter (820-hose) Gasket 15/16 OD x 9/16 ID 1/16 Plastic Box	1 15 1 1 1 5
153 151B	Toll Roll Kit Box, 35 x 13-3/4 x 14-1/4	1 1
- - -	Instruction Booklet Chlorine Manual Parts List	2 1 1

\*Note: Emergency Kit B weighs 110 lbs.

\*\*Note: Viton @ fluoroelastomer is a registered trademark

of E. I. du Pont de Nemours, Inc.

Authorized, trained personnel equipped with suitable respiratory equipment should investigate chlorine leaks promptly. All other persons should be restricted from the affected area. Breathing apparatus or other personal protective equipment are not included in the kits, but must be used when investigating and correcting chlorine leaks and are available from Bisan Trading & Industrial Services Inc.

(Kit Manufactured by Indian Springs Specialty Products, Inc.)



**DEVICE 9**